CHAITANYA GODAVARI GRAMEENA BANK

(A Government undertaking sponsored by Union Bank of India) Head Office, Raghu Mansion, 4/1, Brodipet, Guntur-522 002, A.P.

DEPT: PREMISES & SERVICES DATE: 08.07.2024 Guntur

Addendum -I

RFP for Empanelment of Technical & Commercial empanelment of Vendors for supply, installation, testing, commissioning and maintenance of Batteries and UPS

Tender Reference : Ref. No.099/51/RFP/2024-25/04, Date: 21.06.2024

Date of Addendum : 08.07.2024

Purpose of Addendum:

Amendments in RFP document ------ Page Nos - 15,42 & 47 Clarifications in RFP document ------ Page Nos - 05,07,08,17,27 & 28

Amendments:

Pag e	Current Clause details	To be amended as	
15	Scoring Parameter Desktop evaluation I - based on compliance to general eligibility criteria and specification. Desktop evaluation Component II - based on the previous experience of the bidder in supply, installation, testing, commissioning and maintenance of Batteries and UPS. Service centres, support strength etc. credentials.	UPS evaluation I - based on compliance to general eligibility criteria and specification. UPS evaluation Component II based on the previous experience of the bidder in supply, installation, testing, commissioning and maintenance of Batteries and UPS. Service centres, support strength etc. credentials	
42	Annexure-II: (Business rules and Terms & Conditions of Reverse Auction) TCO shall encompass but not limited to the following: a.) Cost of supply of Passbook Printers (Part-I), Ink Tank Printers (Part-II) and Dot Matrix Printers (Part-III). b.) Cost for installation, testing and commissioning Passbook Printers (Part-I), Ink Tank Printers (Part-II) and Dot Matrix Printers (Part-III)	Annexure-II: (Business rules and Terms & Conditions of Reverse Auction)	
47	Annexure-RA-1: 1. We	Annexure-RA-1: We	



CHAITANYA GODAVARI GRAMEENA BANK

(A Government undertaking sponsored by Union Bank of India) Head Office, Raghu Mansion, 4/1, Brodipet, Guntur-522 002, A.P.

Clarifications:

Page No.	Clause	Clarification sought	Clarification given
05	3.2. Period of validity: The bidder should be a manufacturer of the equipment for the above equipment during the last 3 years 3.3. The Bidder should have executed contracts for supply, installation, testing, commissioning and maintenance of the equipment for which the tender is submitted to public/ private sector banks/government undertakings during the last 2 years.	Whether the Bidder should be an OEM of UPS.	It is confirmed that the bidder should be an OEM (manufacturer of the equipment). No change in the RFP terms and conditions
05	3.3. The Bidder should have supplied minimum 100 UPS of own make (3 KVA & above) in last three financial years to public/ private sector banks/ government undertakings in India.	Proposed to change - The Bidder should have supplied minimum 100 UPS of own make (2 KVA & above) in last three financial years to public/ private sector banks/ government undertakings in India.	No change in the RFP terms and conditions
07,08	RFP Fee is exempted for the Bidders having the NSIC Certificate or MSE Certificate; Bidder has to submit the valid proofs from NSIC at the time of Bid submission EMD is exempted for the Bidders having the NSIC Certificate or MSE Certificate; Bidder has to submit the valid proofs from NSIC at the time of Bid submission. But NSIC/MSE certified bidders should submit the "Bid Security Declaration"	Proposed to change - RFP fee & Earnest Money Deposit (EMD) is exempted for the NSIC/MSE/MSME certified bidders	No change in the RFP terms and conditions
17	21.1&2. The UPS with Batteries should be delivered within 2 weeks from the date of purchase order and installation to be completed within 2 days from the date of delivery. The delivery of Batteries may be within 2 to 3 days from the date of purchase order.	Requested change in the delivery dates of UPS with Batteries to be within 4 to 5 weeks from the date of purchase order and installation to be completed within 10 to 15 days from the date of delivery. The delivery of Batteries may be	No change in the RFP terms and conditions



CHAITANYA GODAVARI GRAMEENA BANK

(A Government undertaking sponsored by Union Bank of India) Head Office, Raghu Mansion, 4/1, Brodipet, Guntur-522 002, A.P.

		within 3 to 4 weeks from the date of purchase order.	
27	2.4. Switching Frequency >= 12 KHz6. Overall efficiency >=84%	Suggested to change - Switching Frequency >= 20 KHz Overall efficiency >=94%	No change in the RFP terms and conditions
28	17. i) ISO 9001:2015 for UPS and battery ii) ISO 14001:2015 for UPS and battery iii) OSHAS 18001:2007 or ISO 45001:2018 for UPS and battery	only for UPS	No change in the RFP terms and conditions

All the other terms and conditions of the RFP read with Addendum-I remain unchanged.

Place: Guntur Date:08.07.2024 P VEERA REDDY GENERAL MANAGER-II